

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7272-1574:183

Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detector

**LISTEE:** ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561  
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

**DESIGN:** Model H2351ADT photoelectric type smoke detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product number, electrical rating and UL label.

**APPROVAL:** Listed as photoelectric type smoke detector for use with listee's separately listed compatible base and fire alarm control units. Suitable for open areas and inside duct installation with air velocities between 0-4000 fpm.

**NOTE:** Formerly 7272-0085:199

**XLf:** 7272-0028:206

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**